

Laboratory Assessment Checklist

Building: Morrill I
 Department: Public Health
 PI: James Hanchett
 Assessor(s): Alesia Fugere

Room: 243
 Date: 10/22/10
 Phone: 545-2601
 Safety Coordinator:

Items for Review:	Yes/No/ NA	Comments
General/Safety/Personal Protective Equipment		
Door card is current	Yes	No response needed
Emergency phone numbers posted by phone	N/A	No response needed
First Aid kit is available	N/A	No response needed
Hand-washing facilities readily accessible, stocked and free of clutter	N/A	No response needed
Eye protection (ANSI 87.1) is available and used when a splash, impact, UV and/or laser hazard is present	Yes	No response needed
Lab coats are worn by personnel when working	Yes	No response needed
Gloves are worn by personnel when working and are appropriate for the task/chemical	Yes	No response needed No response needed
Long pants and closed toed shoes are worn in the lab	Yes	No response needed
No evidence of eating, drinking, make-up application or mouth pipetting	Yes	No response needed
Microwave ovens and ice machines are "For Lab Use Only"	N/A	No response needed
Extension and electrical cords are not overused and /or frayed.	N/A	No response needed
Housekeeping		
The lab is maintained in a clean and orderly condition	Yes	No response needed
Aisles and corridors are free of obstruction and tripping hazards	Yes	No response needed
Storage of vials and tubes is safe and orderly, vials are labeled	Yes	No response needed
Equipment		
<i>Chemical fume hood:</i> Overall appearance is clean, clutter free	N/A	No response needed
<i>Eyewash station</i> is available	N/A	No response needed
Record of weekly eyewash flushing is maintained	N/A	No response needed
Or eyewash bottles are provided (check expiration date)	N/A	No response needed
<i>Vacuum pumps</i> have a guard	N/A	No response needed
are located/maintained in oil & ignition free area	N/A	No response needed
<i>Bunsen Burner</i> hoses are in good condition and are not too long	N/A	No response needed
<i>Freezers</i> are free of ice build up and are free of spills	N/A	No response needed
Chemical Storage		
Containers labeled with name of substance & hazards and are compatibly stored;	Yes Yes	No response needed No response needed
Chemicals in closed containers in good condition, stored upright	Yes	No response needed
Glass containers are off the floor	Yes	No response needed
Chemicals found in drawers or under sinks are stored adequately	Yes	No response needed
Chemical containers are bar-coded	Yes	No response needed
Hydrofluoric Acid is used in this lab	N/A	No response needed

Laboratory Assessment Checklist

Flammable liquids (including acetic acid) are stored in flammable cabinets or refrigerators	N/A	No response needed
Acids are separated from bases/alkalis and are all are stored below eye level	Yes	No response needed
Oxidizers (nitric acid) are separated from organics (e.g., acetic acid, formic acid and flammables)	N/A	No response needed
Peroxide formers (ether, tetrahydrofuran, etc.) dated & used within 6 months of opening	N/A	No response needed
Chemical storage areas are free of ignition sources	Yes	No response needed
Waste Management		
Personnel have the correct containers.	N/A	No response needed
The containers are not overfilled.	N/A	No response needed
Bar code labels have been removed from chemicals.	N/A	No response needed
Satellite accumulation areas inspected weekly and recorded	N/A	No response needed
Waste labels are filled out correctly	N/A	No response needed
Containers are closed and in good condition for transport and are in secondary containment (incompatibles are separated)	N/A	No response needed No response needed
No multiple containers per waste stream (OK to have one working container and one waiting for pick-up)	N/A	No response needed
Trash bins and Glass Only boxes are dry and not over-filled	N/A	No response needed
Sharps boxes are present and not over-filled	N/A	No response needed
Only rinsed, dry glass is found in "Glass Only" boxes	N/A	No response needed
Secondary waste containers are free of spills	N/A	No response needed
Compressed Gas Cylinders		
Are secured with straps/chains without excessive ganging	Yes	No response needed
Contents are labeled, caps are on, not blocking means of egress	Yes	No response needed
BSL-1 and BSL-2 Biohazards		
Bio waste containers are marked with biohazard symbol, not overfilled, lined with red bags, and are covered by a lid	N/A	No response needed No response needed
<i>Vacuum lines</i> are protected with a double-trap and in-line filter located between the last trap and vacuum source.	N/A N/A	No response needed No response needed
Liquid waste is disinfected. Acceptable practices: 10% bleach (made fresh daily) before drain disposal or by autoclaving.	N/A	No response needed No response needed
Biohazard labels on equipment used at BSL-2: centrifuges, incubators, freezers, refrigerators, biosafety cabinets, etc.	N/A	No response needed
Centrifuges have containment vessels in use (caps, sealed rotors,)	N/A	No response needed
Aerosol producing equipment is used in BSC with BSL-2 work	N/A	No response needed
Safety Training		
Lab personnel have attended required annual trainings	Yes	No response needed
Personnel know what to do in case of an accidental biological or chemical spill? Personal exposure or injury? Fire?	Yes	No response needed
Other		